

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Wormald Australia Pty Ltd	Client ID	104656
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.5-2007 : Portable fire extinguishers - Specific requirements for powder type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	8/05/2018	Certification Expiry Date	19/09/2019
Certificate Issue Date	8/05/2018	Certificate Last Update Date	8/05/2018

APPROVED COMPANY/SITE ADDRESS(ES):

38 South Street Rydalmere 2116 NSW Australia

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Unique Certificate Code: **D54C88B9718740F4CA2582740027E53D**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





global-mark®

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
EG1.0ABE	1.0 kg ABE Powder type fire extinguisher	Exelgard	1.0 kg ABE powder, Rating: 2A:10B:E, FERN: 4656.05-100	12/04/2018
WA1.0ABE	1.0 kg ABE Powder type fire extinguisher	Wormald	1.0 kg ABE powder, Rating: 2A:10B:E, FERN: 4656.05-200	12/04/2018
EG1.5ABE	1.5 kg ABE Powder type fire extinguisher	Exelgard	1.5 Kg ABE Powder, Rating: 3A:10B:E, FERN: 4656.05-101	12/04/2018
WA1.5ABE	1.5 kg ABE Powder type fire extinguisher	Wormald	1.5 kg ABE Powder, Rating: 3A:10B:E, FERN: 4656.05-201	12/04/2018
EG2.5ABE	2.5 kg ABE Powder type fire extinguisher	Exelgard	2.5 kg ABE Powder, Rating: 4A:40B:E, FERN: 4656.05-102	12/04/2018
WA2.5ABE	2.5 kg ABE Powder type fire extinguisher	Wormald	2.5 kg ABE Powder, Rating: 4A:40B:E, FERN: 4656.05-202	12/04/2018
EG4.5ABEHP	4.5 kg ABE Powder type fire extinguisher - High Performance	Exelgard	4.5 kg ABE Powder, Rating: 6A:80B:E, FERN: 4656.05-105	12/04/2018
WA4.5ABE	4.5 kg ABE powder type fire extinguisher	Wormald	4.5 kg ABE Powder, Rating: 6A:60B:E, FERN: 4656.05-203	12/04/2018
WA4.5ABEHP	4.5 kg ABE powder type fire extinguisher	Wormald	4.5 kg ABE Powder, Rating: 6A:80B:E, FERN: 4656.05-204	12/04/2018
EG9.0ABE	9.0 kg ABE powder type fire extinguisher	Exelgard	9.0 kg ABE powder, Rating: 10A:80B:E, FERN: 4656.05-104	12/04/2018
WA9.0ABE	9.0 kg ABE powder type fire extinguisher	Wormald	9.0 kg ABE powder, Rating: 10A:80B:E, FERN: 4656.05-205	12/04/2018

Comments:

End of the document



Certification Manager

Hevi Ndha